



Report #: 82911620

Date : 8/29/2011

P.O.Number: 8/29/11 Visa

Same as Client

Matrix: Water

Client: Assabet Sand & Gravel

Sample 16 Knox Trail

Location Acton MA 01776

This sample taken by Doug Macone at 8:00:00 AM on
8/28/2011. . Point of collection: #3 Location

Miscellaneous Scan Report

Results

EPA Limits

Misc. Tests

Fecal E. Coli Count	148 cfu/100mL	MA DEP Criteria less than 235 cfu/100ml initial
---------------------	---------------	---

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested.
Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.